



Government Of West Bengal  
Office Of The Divisional Fire Officer, Hooghly  
West Bengal Fire & Emergency Services  
G.T. Road, Bose Pare, Mahesh-1, Serampore,  
Hooghly, Pin :- 712202

Memo No : WBFES/HGLY/FSR/DN-113/16/R-104/17

Date : 29-06-2021

From:  
Divisional Fire Officer, Hooghly  
West Bengal Fire & Emergency Services

To PEARL ROSARY SCHOOL NEW  
Dakshin Rajyadharpur, P.O.: Mallickpara, P.S.-Serampore, District - Hooghly, Pin-712203

Sub: Renewal of fire safety certificate of an existing G+3 storage building group of occupancy educational building in the name & style of "Pearl Rosary School New" at Dakshin Rajyadharpur, P.O.: Mallickpara, P.S.-Serampore, District - Hooghly, Pin-712203.

This is in reference to your application no. : 0125191210200045 dated 15-06-2021 regarding the Renewal of fire safety certificate of an existing G+3 building group of occupancy Educational building in the name & style of Pearl Rosary School New at Dakshin Rajyadharpur, Serampore Under Dakshin Rajyadharpur Gram Panchayet, Hooghly-712203

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.


However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation :

1. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of the building shall be made with low flame spread material conforming to the I.S. Specification.
3. To eliminate risk of Fire Hazard, Good House keeping both for insides and outsides of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.

The authenticity of this document can be verified by accessing the URL [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191210200045.

Page : 1



*R. Chatterjee*

5. A fire control room including a closed circuit T.V. system will have to be installed which observes entire of the buildings.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the Building.
7. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
8. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction confirming I.S. Specification.
10. A crew of trained Fireman under an experience officer shall be maintained round the clock for safety of the building.
11. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
12. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condion at all the times.
13. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
14. Side open space and stair case of the building shall be free from any type of obstruction.
15. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
16. Fire license to be obtained from the License Department of W.B.F&E.S. for storing combustible materias.
17. All the electrical cable should be paint by fire stop paint to check the spread of fire.
18. If anything happens for improper life safety measure in the building within this period then authority of the said School will be responsible for that.
19. The renewal of fire safety certificate is valid for three years and has to be renewed every three year from the date of issue of this letter.
20. Each after three years a certificate is to be obtained from the Divisional Fire Officer, Hooghly Divn, West Bengal Fire &

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191210200045.

Page : 2



R. Chakravarty

emergency Services performance of all the life & Fire safety arrangements and installations of the building.

21. Any deviation and changes the nature of use of the building in respect of the approved plan drawing without obtaining prior permission from the office of Divisional officer Hooghly division, shall be treated as cancelled.

Signature valid

Digitally signed by TAPAN  
KUMAR B

Date: 2021.06.29 12:16:35 IST

Divisional Fire Officer, Hooghly  
West Bengal Fire & Emergency Services

Memo No. WB/FES/HGLY/FSR/DN/104/17



*R. Chakravarty*