



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo No : FSR/0125186240200095

Date : 11-07-2024

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To : Pearl Rosary School (NEW)
Dakshin Rajyadharpur, P.O Mallickpara, P.S Serampore
District- Hooghly, West Bengal , Pin - 712203

Sub : Renewal of fire safety certificate of an existing G+3 storied building group of occupancy Educational Building in the name & style of "Pearl Rosary School (NEW)" at Dakshin Rajyadharpur, P.O Mallickpara, P.S Serampore , District- Hooghly, West Bengal , Pin - 712203.

This is in reference to your application no. : 0125191210200254 dated 02-07-2024 regarding the Renewal of Fire Safety Certificate of an existing G+3 storied building group of occupancy Educational Building in the name & style of Pearl Rosary School (NEW) at Dakshin Rajyadharpur, P.O Mallickpara, P.S Serampore , District- Hooghly, West Bengal , Pin -712203..

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation :


1. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of the building shall be made with low flame spread material conforming to the I.S. Specification.
3. To eliminate risk of Fire Hazard, Good House keeping both for insides and outsides of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191210200254.

11/07/24
Page: 1

PRINCIPAL

PEARL ROSARY SCHOOL
Affiliated to CBSE
Affiliation Number : 2430413
Hooghly, West Bengal

Powered By  For secure Paperless solutions
Please visit www.emsigner.com

5. A fire control room including a closed circuit T.V. system will have to be installed which observes entire of the buildings.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the Building.
7. The employees and security staffs shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
8. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction confirming I.S. Specification.
10. A crew of trained Fireman under an experience officer shall be maintained round the clock for safety of the building.
11. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
12. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
13. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
14. Side open space and stair case of the building shall be free from any type of obstruction.
15. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
16. Fire license to be obtained from the License Department of W.B.F&E.S. for storing combustible materials.
17. All the electrical cable should be paint by fire stop paint to check the spread of fire.
18. If anything happens for improper life safety measure in the building within this period then authority of the said School will be responsible for that.
19. Periodical flashing of water from the hydrants & sprinkler pipe line shall be made to maintain the efficient working performance of above mentioned system.
20. Fire pump always to be kept in auto mode condition.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191210200254.

Page : 2

11/07/24
PRINCIPAL
PEARL ROSARY SCHOOL
Affiliated to CBSE
Affiliation Number : 2430413
Hooghly, West Bengal

Powered By  emSigner

For secure Paperless solutions
Please visit www.emsigner.com

21. This Fire Safety Certificate is valid for three years from date of issue & have to be regularized within the validity limit from the date of issue of this letter from the Director General, West Bengal Fire & Emergency Services.

Signature valid

Digitally signed by ABHIJIT
PANDEY

Date: 2024/07/11 11:16:25 IST



Director
West Bengal Fire & Emergency Services

Memo No : FSR/0125186200095

11/07/24

PRINCIPAL
PEARL ROSARY SCHOOL
Affiliated to CBSE
Affiliation Number : 2430413
Hooghly, West Bengal